

**ISHPEMING CITY COUNCIL SPECIAL MEETING**  
**Wednesday, May 23, 2018 at 10:00 a.m.**  
**Ishpeming City Hall, 100 E. Division Street, Ishpeming, MI 49849**  
**City Hall Telephone Number: 906-485-1091**

---

Meeting Called to Order

Roll Call

Agenda Comment

AGENDA ITEMS

1. Emergency Sewer Repair Change Order – Water Improvement Project



Mark Slown  
City Manager

## City Manager

---

**From:** Stoor, Mark <mstoor@geiconsultants.com>  
**Sent:** Tuesday, May 22, 2018 10:13 AM  
**To:** City Manager  
**Cc:** Cathy Smith; DPW Director; Fabbri, Brian  
**Subject:** Potential Contract Change - RD Water Project

Hi Mark,

As discussed, we crossed a sanitary sewer on summit street with our water main, and based on the difficulty in reconnection and condition at connection, we recommend replacing this sewer pipe in full between manholes. There is approximately 190' of sewer between manholes that will need to be replaced, for an estimated cost of \$7,000. It would be replaced with the water project.

In most cases, we run parallel to the sewer or cross it perpendicular, however in this case, we crossed at a diagonal, which exposed more of the sewer, and made for a larger patch.

If you have any questions, please let me know. Otherwise, we will be at a meeting to answer any questions.

Thank you,

Mark

**Mark F. Stoor, P.E.**  
Senior Project Engineer



GEI Consultants of Michigan, P.C.  
990 Lalley Road | Iron River, MI 49935  
T: 906.214.4147 | M: 906.284.3552 | F: 906.214.4141  
[www.geiconsultants.com](http://www.geiconsultants.com) | [vCard](#) | [map](#) | [LinkedIn](#) | [Twitter](#) | [Facebook](#)